

CITY OF NEWARK
Delaware

CONTRACT NO. 14-05

CORBIT STREET AREA WATER MAIN REPLACEMENT

ADDENDUM NO. 2

June 5, 2014

1. Residential house services shall be $\frac{3}{4}$ " type K copper.
2. $\frac{3}{4}$ " water services can be direct tapped into new ductile iron pipe.